

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Temp chlor

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
4/4	Rm 26	7.6	572	0.8	/	Y
4/15		7.5	58.1	1.0	/	Y
4/19		7.8	56.3	1.0	/	Y
4/25		7.9	57.9	1.0	/	Y

<Has sample met the minimum(s)? **DISTRIBUTION**  
County: Lincoln Agency: LINCOLN C

**PWS ID 4192040**  
**EDDYVILLE CHARTER SCHOOL**

Sample Period: April 2022  
Month/Year  
Sample Frequency: Every 6 months  
Distribution Samples required: 1

Number of excursions during this Sample Period = 0  
(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

(N = No = Excursion) Total N's 0

Print Name: Jason Books  
Signature: [Signature]  
Date: 5-10-22