

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Temp chlor

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
517	Rm. 26	7.8	61.7	0.8	/	Y
512		7.9	62.1	0.8	/	Y
518		7.9	62.8	0.6	/	Y
5126		7.8	62.6	0.8	/	Y

<Has sample met the minimum(s)?

County: Lincoln Agency: LINCOLN C

**DISTRIBUTION**

PWS ID 4192040  
 EDDYVILLE CHARTER SCHOOL

Sample Period: May 2022  
Month/Year  
 Sample Frequency: Every 6 months  
 Distribution Samples required: 1

Number of excursions during this Sample Period = 0  
 (Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:  
 pH 7.2

(N = No = Excursion) Total N's 0

Print Name: Jason Brooks  
 Signature: [Signature]  
 Date: 6-9-22