

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Temp Chlor

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
6/2	Rm 26	7.9	63.2	0.8	/	y
6/8		7.9	64.1	1.0	/	y
6/16		7.9	64.2	0.8	/	y
6/27		7.8	63.7	0.8	/	y

<Has sample met the minimum(s)?

County: Lincoln Agency: LINCOLN C

DISTRIBUTION

PWS ID 4192040

EDDYVILLE CHARTER SCHOOL

Sample Period: June 2022
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

(N = No = Excursion) Total N's 0

Print Name: Jasen Brooks
Signature: [Signature]
Date: 6/28 7-8-2022

Send to Drinking Water Program within 10 days after end of sampling period:
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>