Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	~~Alk~~ temp	~~PO4~~ chlor	Other	Y/N
10/3	Rm 26	8	60	.3	✓	Y
10/10	"	8	60	.4	✓	Y
10/17	"	8	59.8	.3	✓	Y
10/20	"	7.9	58.5	.2	✓	Y
10/25	"	7.8	57	.3	✓	Y
10/31	"	8	57.1	.2	✓	Y
11/2	"	8	57.5	.4		Y

(N = No = Excursion) **Total N's** Ø

<Has sample met the minimum(s)?

County: Lincoln Agency: LINCOLN C

DISTRIBUTION

PWS ID 4192040

EDDYVILLE CHARTER SCHOOL

Sample Period: Oct/2022
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 1

Number of excursions during this Sample Period = Ø

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Jenny Wheeler
Signature: [signature]
Date: 11/2/22

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/