Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	TEMP	Chlor	Other	Y/N
2		7.6	53	.5	/	Y
6		7.6	52	.5	/	Y
8		7.5	53	.4	/	Y
14		7.5	51	.4	/	Y
16		7.4	52	.2	/	Y
21		7.4	53	.2	/	Y
23		7.4	53	.2	/	Y

(N = No = Excursion) **Total N's** Ø

<Has sample met the minimum(s)?

County: Lincoln Agency: LINCOLN C

DISTRIBUTION

PWS ID 4192040

EDDYVILLE CHARTER SCHOOL

Sample Period: Feb - 23
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Danny Wheeler
Signature: [signature]
Date: 3-7-23

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/