

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

ID #	Sample Location	pH	Temp	Chlor	Other	Y/N
3	WR	7.5	53	.5	/	Y
6	"	7.5	53	.5	/	Y
11	"	7.4	52	.4	/	Y
13	"	7.2	52	.4	/	Y
17	"	7.4	53	.4	/	Y
19	"	7.6	53	.5	/	Y
24	"	7.5	53	.5	/	Y
26	"	7.5	53	.4	/	Y

County: Lincoln Agency: LINCOLN C  
**DISTRIBUTION**  
**PWS ID 4192040**  
**EDDYVILLE CHARTER SCHOOL**  
 Sample Period: April / 23  
Month/Year  
 Sample Frequency: Every 6 months  
 Distribution Samples required: 1

Number of excursions during this Sample Period = 0  
 (Number of locations when any WQP was less than the minimum.)  
 Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference  
 Minimum Water Quality Parameters as set by State:  
 pH 7.2

(N = No = Excursion) Total N's

Print Name: Danny Wheeler  
 Signature: [Signature]  
 Date: 5/3/23