

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Temp	Chlor	Other	Y/N
8/1	Work Room	7.8	56.2	.5	/	Y
8/3	'	7.7	56.1	.4	/	Y
8/8	'	7.9	56	.5	/	Y
8/10	'	8	56	.6	/	Y
8/15	'	8	56.1	.6	/	Y
8/17	'	7.9	56.1	.6	/	Y
8/22	'	7.9	56.2	.5	/	Y
8/24	'	7.8	56.3	.5	/	Y
8/29	'	7.8	56.1	.5	/	Y
8/31	'	7.8	56.1	.5	/	X

<Has sample met the minimum(s)?

County: Lincoln Agency: LINCOLN C

DISTRIBUTION

PWS ID 4192040

EDDYVILLE CHARTER SCHOOL

Sample Period: 8/23
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Danny Wheeler
Signature: [Signature]
Date: 9/5/23

(N = No = Excursion) Total N's 1

Send to Drinking Water Program within 10 days after end of sampling period:
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>