Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Temp	Chlor	Other	Y/N
5/2		7.6	60	.4	X	Y
5/6		7.6	59	.5	X	Y
5/8		7.6	59.5	.3	X	Y
5/14		7.5	60	.5	X	Y
5/16		7.6	60	.4	X	Y
5/21		7.6	61	.4	X	Y
5/23		7.4	59	.4	X	Y
5/28		7.5	60	.5	X	Y
5/30		7.5	60.5	.4	V	Y

(N = No = Excursion) **Total N's** Ø

<Has sample met the minimum(s)?

County: Lincoln Agency: LINCOLN C

DISTRIBUTION

PWS ID 4192040

EDDYVILLE CHARTER SCHOOL

Sample Period: 5 / 24
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 1

Number of excursions during this Sample Period = Ø

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Danny Wheeler
Signature: [signature]
Date: 6/3/24

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/