

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	TEMP	Chlor	Other	Y/N
4/1	Health Room	7.8	59.5	/	/	Y
8/5	"	7.8	59.5	/	/	Y
8/7	"	7.8	58.4	/	/	Y
8/13	"	7.9	58.5	/	/	Y
8/15	"	7.8	58.5	/	/	Y
8/20	"	7.9	59.4	/	/	Y
8/22	"	7.9	59.4	/	/	Y
8/27	"	8.1	60.4	/	/	Y
8/29	"	8.1	60.4	/	/	Y

<Has sample met the minimum(s)?

County: Lincoln Agency: LINCOLN C

DISTRIBUTION

PWS ID 4192040

EDDYVILLE CHARTER SCHOOL

Sample Period: 8/20
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 1

Number of excursions during this Sample Period =

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

(N = No = Excursion) Total N's 8

Print Name: Danny Wheeler
Signature: [Signature]
Date: 9/8/04

Send to Drinking Water Program within 10 days after end of sampling period:
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>