

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Temp	Chlor	Other	Y/N
2		7.4	56	.3	/	Y
4		7.4	56.3	.4	/	Y
9		7.5	56	.3	/	Y
11		7.5	55	.3	/	Y
16		7.6	56	.4	/	Y
18		7.7	56	.3	/	Y
23		7.7	55	.3	/	Y
25		7.7	56	.4	/	Y
30		7.2	56	.4	/	Y

<Has sample met the minimum(s)?

County: Lincoln Agency: LINCOLN C

DISTRIBUTION

PWS ID 4192040

EDDYVILLE CHARTER SCHOOL

Sample Period: _

Dec 2014 
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference _____

Minimum Water Quality Parameters as set by State:

pH 7.2

(N = No = Excursion) Total N's

Print Name: Danny Wheeler
Signature: [Signature]
Date: 12/4/14

Send to Drinking Water Program within 10 days after end of sampling period:
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>