

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				y
2	7.3				y
3	7.4				y
4	7.5				y
5	7.4				y
6	7.4				y
7	7.4				y
8	7.4				y
9	7.4				y
10	7.4				y
11	7.4				y
12	7.4				y
13	7.4				y
14	7.6				y
15	7.6				y
16	7.6				y
17	7.5				y
18	7.5				y
19	7.6				y
20	7.6				y
21	7.6				y
22	7.8				y
23	7.8				y
24	7.8				y
25	7.3				y
26	7.3				y
27	7.0				n
28	7.0				n
29					
30					
31					

(No = N = Excursion) **Total N's** 0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 92641

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: February 2021

Month/Year

Number of excursions* during this month: 2

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 3

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.20
 Alk *(Alkalinity)*
 PO4 *(Orthophosphate)*
 Other *(_____)*

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 3-9-2021

Send to DWP within 10 days after end of sampling period