

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.0	* soda ash pump			n
2	7.2	failed			y
3	7.2				y
4	7.4				y
5	7.4				y
6	7.6				y
7	7.8				y
8	7.8				y
9	7.6				y
10	7.4				y
11	7.3				y
12	7.3				y
13	7.4				y
14	7.4				y
15	7.0				n
16	7.4				y
17	7.5				y
18	7.5				y
19	7.6				y
20	7.6				y
21	7.6				y
22	7.4				y
23	7.4				y
24	7.4				y
25	7.4				y
26	7.4				y
27	7.6				y
28	7.7				y
29	7.9				y
30	7.9				y
31	7.8				y

(No = N = Excursion) **Total N's** 0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 92641

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: March 2021

Month/Year

Number of excursions* during this month: 2

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 7

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.20	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 4-2-2021

Send to DWP within 10 days after end of sampling period