

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.90				y
2	7.90				y
3	7.80				y
4	7.60				y
5	7.40				y
6	7.40				y
7	7.40				y
8	7.40				y
9	7.40				y
10	7.40				y
11	7.40				y
12	7.00				n
13	7.40				y
14	7.30				y
15	7.30				y
16	7.10				n
17	7.00				y
18	6.50				n
19	6.50				n
20	7.20				y
21	7.30				y
22	7.30				y
23	7.50				y
24	7.60				y
25	7.60				y
26	7.60				y
27	7.60				y
28	7.60				y
29	7.80				y
30	7.60				y
31					y

(No = N = Excursion) **Total N's** 4

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 2 6 4 1

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: March 2021
Month/Year

Number of excursions* during this month: 4
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 7
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.20	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 5-10-2021

Send to DWP within 10 days after end of sampling period