

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6				y
2	7.6				y
3	7.7				y
4	7.8				y
5	7.7				y
6	7.7				y
7	7.7				y
8	7.7				y
9	7.6				y
10	7.6				y
11	7.6				y
12	7.7				y
13	7.6				y
14	7.6				y
15	7.7				y
16	7.7				y
17	7.5				y
18	7.7				y
19	7.7				y
20	7.7				y
21	7.6				y
22	7.6				y
23	7.6				y
24	7.7				y
25	7.7				y
26	7.6				y
27	7.7				y
28	7.7				y
29	7.6				y
30	7.6				y
31	7.7				

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID:** 41 9 2 6 4 1

**System Name:** USFS Timberline Lodge 1

**Entry Point:** EP-A

**Sample Period:** October 2022  
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

### Minimum Water Quality Parameters as set by

pH 7.20

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

**Print Name:** Phillip Merrill

**Signature:** *Phillip Merrill*

**Date:** 11-9-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0