

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.1				y
2	8.1				y
3	8.1				y
4	8.2				y
5	7.8				y
6	7.9				y
7	7.9				y
8	7.9				y
9	7.9				y
10	7.8				y
11	7.8				y
12	7.9				y
13	8.1				y
14	7.9				y
15	7.8				y
16	7.8				y
17	7.7				y
18	7.7				y
19	7.8				y
20	7.9				y
21	7.8				y
22	7.8				y
23	7.4				y
24	7.7				y
25	7.7				y
26	7.7				y
27	7.7				y
28	7.7				y
29	7.9				y
30	7.7				y
31					

<<Have minimums been met for this day?

## ENTRY POINT

PWS ID: 41

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: July 2023  
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.20"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Phillip Merrill

Signature: Phillip Merrill

Date: 8-7-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's