

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9				y
2	7.9				y
3	7.9				y
4	7.9				y
5	7.9				y
6	7.9				y
7	7.9				y
8	7.9				y
9	7.8				y
10	7.8				y
11	7.7				y
12	7.7				y
13	7.7				y
14	7.7				y
15	7.7				y
16	7.8				y
17	7.7				y
18	7.8				y
19	7.8				y
20	7.7				y
21	7.8				y
22	7.8				y
23	7.8				y
24	7.8				y
25	7.7				y
26	7.7				y
27	7.6				y
28	7.6				y
29	7.7				y
30	7.8				y
31	7.9				y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: January 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 2-8-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**