

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				y
2	7.4				y
3	7.4				y
4	7.4				y
5	7.4				y
6	7.4				y
7	7.4				y
8	6.8				n
9	7.0				n
10	7.3				y
11	7.3				y
12	7.2				y
13	7.1				n
14	7.1				n
15	7.1				n
16	7.1				n
17	7.1				n
18	7.1				n
19	7.2				y
20	7.3				y
21	7.2				y
22	7.3				y
23	7.4				y
24	7.3				y
25	7.3				y
26	7.4				y
27	7.4				y
28	7.4				y
29	7.4				y
30	7.4				y
31	7.4				y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: May 2024
Month/Year

Number of excursions* during this month: 8

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.20"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Phillip Merrill

Signature: Phillip Merrill

Date: 6-6-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's