

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.2				y
2	8.2				y
3	8.2				y
4	8.2				y
5	8.2				y
6	8.2				y
7	8.1				y
8	8.1				y
9	8.1				y
10	8.0				y
11	8.0				y
12	8.0				y
13	8.0				y
14	8.0				y
15	7.8				y
16	7.6				y
17	7.6				y
18	7.4				y
19	7.3				y
20	7.4				y
21	7.4				y
22	7.5				y
23	7.3				y
24	7.5				y
25	7.5				y
26	7.5				y
27	7.5				y
28	7.5				y
29	7.5				y
30	7.5				y
31	7.4				y

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID:** 41

**System Name:** USFS Timberline Lodge 1

**Entry Point:** EP-A

**Sample Period:** August 2024  
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 9  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

### Minimum Water Quality Parameters as set by

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

**Print Name:** Phillip Merrill

**Signature:** *Phillip Merrill*

**Date:** 9-6-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**