

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.1				y
2	8.1				y
3	8.1				y
4	8.1				y
5	8.1				y
6	8.1				y
7	8.1				y
8	8.1				y
9	8.1				y
10	8.1				y
11	8.1				y
12	8.1				y
13	8.1				y
14	8.0				y
15	8.0				y
16	7.7				y
17	7.7				y
18	7.6				y
19	7.6				y
20	7.4				y
21	7.7				y
22	7.7				y
23	7.7				y
24	7.6				y
25	7.4				y
26	7.3				y
27	7.3				y
28	7.2				y
29	6.9				n
30	6.9				n
31	6.9				n

(No = N = Excursion) **Total N's** 3

<<Have
 minimums
 been met for
 this day?

ENTRY POINT
PWS ID: 41 92641
System Name: USFS Timberline Lodge 1
Entry Point: EP-A
Sample Period: December 2024

Month/Year

Number of excursions* during this month: 3
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 3
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.20
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Phillip Merrill

Signature: Phillip Merrill

Date: 1-9-2025

Send to DWP within 10 days after end of sampling period