

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	6.9				n
2	6.9				n
3	6.9				n
4	6.9				n
5	6.8				n
6	6.8				n
7	7.1				n
8	6.8				n
9	8.5				y
10	8.2				y
11	8.1				y
12	7.6				y
13	7.4				y
14	7.7				y
15	8.0				y
16	8.1				y
17	8.1				y
18	8.1				y
19	8.1				y
20	8.5				y
21	8.5				y
22	8.5				y
23	8.5				y
24	7.9				y
25	7.7				y
26	7.6				y
27	8.0				y
28	8.1				y
29	8.1				y
30	8.1				y
31	8.2				y

(No = N = Excursion) **Total N's** 8

<<Have
 minimums
 been met for
 this day?

ENTRY POINT
PWS ID: 41 92641
System Name: USFS Timberline Lodge 1
Entry Point: EP-A
Sample Period: January 2025

Month/Year

Number of excursions* during this month: 8
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 6
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.20	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 2-4-2025

Send to DWP within 10 days after end of sampling period