

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.1				y
2	8.0				y
3	8.1				y
4	8.1				y
5	8.1				y
6	8.2				y
7	8.1				y
8	8.1				y
9	8.1				y
10	7.8				y
11	8.3				y
12	8.5				y
13	8.2				y
14	8.5				y
15	7.9				y
16	7.8				y
17	7.5				y
18	7.6				y
19	7.6				y
20	8.0				y
21	8.1				y
22	8.4				y
23	8.7				y
24	9.1				y
25	9.0				y
26	8.9				y
27	9.0				y
28	9.0				y
29					y
30					y
31					y

(No = N = Excursion) **Total N's** 0

<<Have
 minimums
 been met for
 this day?

ENTRY POINT
PWS ID: 41 92641
System Name: USFS Timberline Lodge 1
Entry Point: EP-A
Sample Period: February 2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 14
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.20	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Phillip Merrill
Signature: *Phillip Merrill*
Date: 3-7-2025

Send to DWP within 10 days after end of sampling period