

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				y
2	8.0				y
3	7.6				y
4	7.5				y
5	7.8				y
6	7.8				y
7	7.9				y
8	8.0				y
9	7.4				y
10	8.2				y
11	8.0				y
12	7.5				y
13	7.4				y
14	7.4				y
15	7.3				y
16	7.7				y
17	7.7				y
18	8.0				y
19	8.0				y
20	8.0				y
21	8.0				y
22	7.9				y
23	7.8				y
24	7.6				y
25	7.6				y
26	7.5				y
27	7.8				y
28	7.4				y
29	7.3				y
30	7.4				y
31					

(No = N = Excursion) **Total N's** 0

<<Have
 minimums
 been met for
 this day?

ENTRY POINT
PWS ID: 41 92641
System Name: USFS Timberline Lodge 1
Entry Point: EP-A
Sample Period: April 2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 12
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.20	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 5-9-2025

Send to DWP within 10 days after end of sampling period