

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				y
2	7.5				y
3	7.5				y
4	7.5				y
5	7.3				y
6	7.2				y
7	7.2				y
8	7.1				n
9	7.1				n
10	7.2				y
11	7.2				y
12	7.0				n
13	7.1				n
14	7.2				y
15	7.2				y
16	7.5				y
17	7.5				y
18	7.6				y
19	7.6				y
20	8.0				y
21	7.9				y
22	8.0				y
23	8.0				y
24	7.8				y
25	8.0				y
26	8.0				y
27	8.1				y
28	8.1				y
29	8.0				y
30	8.0				y
31	8.0				y

(No = N = Excursion) **Total N's** 4

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 92641

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: May 2025
Month/Year

Number of excursions* during this month: 4
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 11
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.20	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 6-6-2025

Send to DWP within 10 days after end of sampling period