

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0				y
2	8.0				y
3	8.0				y
4	8.0				y
5	8.0				y
6	8.0				y
7	7.8				y
8	7.8				y
9	7.8				y
10	8.0				y
11	8.0				y
12	7.8				y
13	8.1				y
14	8.0				y
15	8.0				y
16	8.0				y
17	8.0				y
18	8.0				y
19	8.0				y
20	8.0				y
21	8.0				y
22	8.0				y
23	8.0				y
24	8.0				y
25	8.0				y
26	8.0				y
27	8.0				y
28	8.0				y
29	8.0				y
30	8.0				y
31	8.0				y

(No = N = Excursion) **Total N's** 0

<<Have
 minimums
 been met for
 this day?

ENTRY POINT
PWS ID: 41 92641
System Name: USFS Timberline Lodge 1
Entry Point: EP-A
Sample Period: July 2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 4
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.20
 Alk *(Alkalinity)*
 PO4 *(Orthophosphate)*
 Other *(_____)*

Print Name: Phillip Merrill
Signature: *Phillip Merrill*
Date: 8-9-2025

Send to DWP within 10 days after end of sampling period