

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0				Y
2	8.0				Y
3	8.0				Y
4	8.0				y
5	8.0				y
6	8.0				y
7	8.0				y
8	8.0				y
9	7.8				y
10	7.8				y
11	8.0				y
12	7.6				y
13	7.6				y
14	8.0				y
15	7.8				y
16	8.0				y
17	8.0				y
18	7.5				y
19	6.9				n
20	7.7				y
21	7.8				y
22	7.6				Y
23	8.0				Y
24	8.0				Y
25	8.0				Y
26	8.1				Y
27	8.1				Y
28	8.0				Y
29	8.0				Y
30	8.0				Y
31	8.0				y
(No = N = Excursion) Total N's					1

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

9	2	6	4	1
---	---	---	---	---

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: September 2025

Month/Year

Number of excursions* during this month: 1

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 4

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.20	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Phillip Merrill

Signature: Phillip Merrill

Date: 10-5-2025

Send to DWP within 10 days after end of sampling period