

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.8				Y
3	7.6				Y
4	7.8				y
5	7.7				y
6	7.7				y
7	7.5				y
8	8.0				y
9	7.7				y
10	7.6				y
11	7.7				y
12	7.7				y
13	7.7				y
14	7.7				y
15	7.7				y
16	7.7				y
17	7.7				y
18	7.7				y
19	7.7				y
20	7.7				y
21	7.5				y
22	7.5				Y
23	7.5				Y
24	7.7				Y
25	7.7				Y
26	7.7				Y
27	7.5				Y
28	7.4				Y
29	7.5				Y
30	6.9				n
31	7.4				y
					1

(No = N = Excursion) **Total N's** 1

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

9	2	6	4	1
---	---	---	---	---

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: December 2025

Month/Year

Number of excursions* during this month: 1

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<u>7.20</u>	
Alk	<u></u>	(Alkalinity)
PO4	<u></u>	(Orthophosphate)
Other	<u></u>	(_____)

Print Name: Phillip Merrill

Signature: Phillip Merrill

Date: 1-09-2026

Send to DWP within 10 days after end of
sampling period