

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.3				Y
3	7.5				Y
4	7.5				y
5	7.5				y
6	7.0				n
7	6.9				n
8	7.3				y
9	7.1				N
10	7.0				N
11	7.4				Y
12	7.0				N
13	6.8				N
14	6.3				N
15	6.9				N
16	6.9				N
17	7.1				N
18	6.9				N
19	6.8				N
20	7.0				N
21	6.9				N
22	7.0				N
23	7.3				Y
24	7.3				Y
25	7.4				Y
26	7.4				Y
27	7.3				Y
28	7.4				Y
29	7.3				Y
30	7.3				Y
31	7.4				Y
					15

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

9	2	6	4	1
---	---	---	---	---

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: January 2026
Month/Year

Number of excursions* during this month: 15
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 2
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.20

Alk

--

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 2-4-2026

Send to DWP within 10 days after end of sampling period