

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2	6.8				N
3	6.8				N
4	7.0				N
5	6.9				N
6	6.9				N
7	7.4				Y
8	8.0				Y
9	6.8				N
10	7.0				N
11	6.8				N
12	7.0				N
13	6.9				N
14	7.1				N
15	7.0				N
16	7.4				Y
17	7.2				Y
18	7.1				N
19	7.1				N
20	7.5				Y
21	7.2				Y
22	7.2				Y
23	7.2				Y
24	7.3				Y
25	7.3				Y
26	7.0				N
27	7.2				Y
28	6.9				N
29					
30					
31					
					15

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

9	2	6	4	1
---	---	---	---	---

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: February 2026

Month/Year

Number of excursions* during this month: 16

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 17

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.20

 Alk

--

 (Alkalinity)
 PO4

--

 (Orthophosphate)
 Other

--

 (_____)

Print Name: Phillip Merrill

Signature: Phillip Merrill

Date: 3-10-2026

Send to DWP within 10 days after end of sampling period