

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2	7.3				Y
3	6.9				N
4	7.0				N
5	6.9				N
6	6.9				N
7	6.9				N
8	6.9				N
9	6.9				N
10	6.9				N
11	6.9				N
12	6.8				N
13	6.8				N
14	6.8				N
15	6.8				N
16	6.8				N
17	6.8				N
18	6.8				N
19	6.7				N
20	6.7				N
21	6.7				N
22	6.5				N
23	6.5				N
24	6.7				N
25	6.7				N
26	6.6				N
27	6.7				N
28	7.0				N
29	7.4				Y
30	7.0				N
31	6.8				N
					28

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

9	2	6	4	1
---	---	---	---	---

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: March 2026

Month/Year

Number of excursions* during this month: 28

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 32

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.20

 Alk

--

(Alkalinity)
 PO4

--

(Orthophosphate)
 Other

--

(_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 4-7-2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350