

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				y
2	7.3				y
3	7.3				y
4	7.4				y
5	7.3				y
6	7.4				y
7	7.4				y
8	7.3				y
9	7.3				y
10	7.3				y
11	7.2				y
12	7.2				y
13	7.0				n
14	7.3				y
15	7.3				y
16	7.4				y
17	7.2				y
18	7.2				y
19	7.2				y
20	7.2				y
21	7.2				y
22	7.2				y
23	7.2				y
24	7.2				y
25	7.4				y
26	7.3				y
27	7.3				y
28	7.4				y
29	7.4				y
30	7.4				y
31	7.4				y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 2 6 4 1

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: January 2021
Month/Year

Number of excursions* during this month: 1
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 2
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.20	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 2-8-2021

Send to DWP within 10 days after end of sampling period