

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.1				n
2	7.1				n
3	7.1				n
4	7.1				n
5	7.3				y
6	7.3				y
7	7.2				y
8	7.4				y
9	7.3				y
10	7.2				y
11	7.4				y
12	7.3				y
13	7.2				y
14	7.2				y
15	7.1				n
16	7.1				n
17	7.1				n
18	7.3				y
19	7.2				y
20	9.9				y
21	8.4				y
22	9.2				y
23	9.2				y
24	8.9				y
25	8.5				y
26	8.3				y
27	8.1				y
28	7.9				y
29	7.7				y
30	7.7				y
31	7.5				y

(No = N = Excursion) **Total N's** 7

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 2 6 4 1

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: October 2021
Month/Year

Number of excursions* during this month: 7
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 11
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.20

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 11-7-2021

Send to DWP within 10 days after end of sampling period