

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				y
2	7.4				y
3	7.4				y
4	7.2				y
5	7.4				y
6	7.3				y
7	7.4				y
8	7.6				y
9	7.6				y
10	8.2				y
11	9.0				y
12	9.1				y
13	9.1				y
14	8.0				y
15	7.6				y
16	7.4				y
17	7.6				y
18	7.2				y
19	7.4				y
20	7.4				y
21	7.4				y
22	7.4				y
23	7.4				y
24	7.4				y
25	7.4				y
26	7.4				y
27	7.4				y
28	7.4				y
29	7.3				y
30	7.2				y
31	7.2				y

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID:** 41

**System Name:** USFS Timberline Lodge 1

**Entry Point:** EP-A

**Sample Period:** December 2021  
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 19  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

### Minimum Water Quality Parameters as set by

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

**Print Name:** Phillip Merrill

**Signature:** *Phillip Merrill*

**Date:** 1-7-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**