

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				y
2	7.0				n
3	7.3				y
4	7.3				y
5	7.4				y
6	7.4				y
7	7.5				y
8	7.2				y
9	7.6				y
10	7.8				y
11	8.0				y
12	8.0				y
13	8.0				y
14	7.9				y
15	8.0				y
16	7.8				y
17	7.6				y
18	7.6				y
19	7.6				y
20	7.7				y
21	7.9				y
22	8.0				y
23	8.1				y
24	7.6				y
25	7.6				y
26	7.4				y
27	7.4				y
28	7.4				y
29	7.1				n
30	7.3				y
31	7.3				y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: December 2021

Month/Year

Number of excursions* during this month: 2
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 19
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk *(Alkalinity)*

PO4 *(Orthophosphate)*

Other *(_____)*

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 2-7-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**