

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				y
2	7.3				y
3	7.3				y
4	7.4				y
5	7.5				y
6	7.3				y
7	7.4				y
8	7.4				y
9	7.4				y
10	7.2				y
11	7.4				y
12	7.3				y
13	7.3				y
14	7.4				y
15	7.3				y
16	7.3				y
17	7.2				y
18	7.1				n
19	7.8				y
20	7.4				y
21	7.6				y
22	7.4				y
23	7.2				y
24	7.2				y
25	7.2				y
26	7.2				y
27	7.2				y
28	7.3				y
29					
30					
31					

(No = N = Excursion) **Total N's** 1

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 2 6 4 1

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: February 2022
Month/Year

Number of excursions* during this month: 1
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 19
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.20

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 3-9-2022

Send to DWP within 10 days after end of sampling period