

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.2				y
2	7.9				y
3	8.0				y
4	8.0				y
5	8.0				y
6	8.3				y
7	8.0				y
8	8.0				y
9	8.0				y
10	8.0				y
11	8.0				y
12	8.0				y
13	8.0				y
14	8.0				y
15	7.6				y
16	7.8				y
17	7.8				y
18	7.8				y
19	7.8				y
20	8.0				y
21	7.8				y
22	7.8				y
23	7.8				y
24	7.8				y
25	7.8				y
26	7.8				y
27	7.8				y
28	7.8				y
29	7.8				y
30	7.8				y
31	7.8				y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: May 2022
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 3

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.20"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 6-8-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's