

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.7				y
2	7.6				y
3	7.7				y
4	7.7				y
5	7.6				y
6	7.6				y
7	7.6				y
8	7.7				y
9	7.7				y
10	7.6				y
11	7.7				y
12	7.7				y
13	7.6				y
14	7.6				y
15	7.7				y
16	7.6				y
17	7.6				y
18	7.7				y
19	7.5				y
20	7.7				y
21	7.7				y
22	7.7				y
23	7.7				y
24	7.7				y
25	7.6				y
26	7.6				y
27	7.6				y
28	7.6				y
29	7.6				y
30	7.8				y
31					

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: November 2022
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other (_____)

Print Name: Phillip Merrill

Signature: Phillip Merrill

Date: 12-8-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's