

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.2				y
2	8.1				y
3	8.2				y
4	8.1				y
5	8.1				y
6	8.0				y
7	7.7				y
8	7.7				y
9	7.7				y
10	7.5				y
11	7.7				y
12	7.7				y
13	7.7				y
14	7.7				y
15	7.7				y
16	7.7				y
17	7.6				y
18	7.7				y
19	7.8				y
20	7.8				y
21	7.9				y
22	7.8				y
23	7.8				y
24	7.9				y
25	8.0				y
26	8.0				y
27	8.0				y
28	8.0				y
29	8.0				y
30	8.1				y
31					y

<<Have minimums been met for this day?

## ENTRY POINT

PWS ID: 41

System Name: USFS Timberline Lodge 1

Entry Point: EP-A

Sample Period: April 2023  
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

### Minimum Water Quality Parameters as set by

pH   
 Alk  (Alkalinity)  
 PO4  (Orthophosphate)  
 Other  (\_\_\_\_\_)

Print Name: Phillip Merrill

Signature: Phillip Merrill

Date: 5-3-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's