

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Sili	Y/N	< <have< th=""><th>County: Lane Agency: REGION 2</th></have<>	County: Lane Agency: REGION 2	
1.	2000,000					minimums	ENTRY POINT	
6/3	7.51				Y	been met for this day?	EP(A)	
						tills day?		
6/17	7.64				Y		PWS ID 4192804	
						USFS MCKENZIE RANGER STATION		
							June 2021	
						Sample period:Month/Year		
							Wonth/ Year	
						Number of excursions during this month:0 (Over 9 excursions in 6 months is a violation. Entr.		
		•				Point and Distribution excursions are cumulative).		
						An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the		
						State.		
					-			
						⊢Refe	rence	
							Minimum Water Quality	
							Parameter(s) as set by State:	
							pH 7.2	
-					20			
$\neg \uparrow$					_			
					\neg	e e		
						D :		
						Print Name: Kenny Gabriel		
							7/21	
o = N = Excursion) Total N's 0					0	Send to DWP within 10 days after end of sampling period		

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381 Website: www.dhs.state.or.us/publichealth/dwp/index.cfm