

Day	pH	Alk	Phos	Sili	Y/N
7/9	7.75				Y
7/23	7.73				Y

<<Have
minimums
been met for
this day?

County: Lane Agency: REGION 2

ENTRY POINT

EP **A**

PWS ID 4192804

USFS MCKENZIE RANGER STATION


Sample period: 7/21
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entr. Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Kenny Gabriel
 Signature: 
 Date: 8/9/21

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period