

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Sili	Y/N	< <have< th=""><th>County: Lane Agency: REGION 2</th></have<>	County: Lane Agency: REGION 2	
1						minimums	ENTRY POINT	
5/3	7.28				Y	been met for	EP (A)	
313	,.20					this day?		
5/17	7.4				Y	PWS ID 4192804 USFS MCKENZIE RANGER STATION		
5/31	7.44				Y	Sample period: May/23 Month/Year Number of excursions during this month:0		
	,							
						(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.		
						Refe	rence	
							Minimum Water Quality Parameter(s) as set by State:	
						er e	pH 7.2	
						Print Name:		
-						Signature: Kenneth Gabriel		
+			-			Date:6/10	0/2023	
o = N = Excursion) Total N's						Send to DWP within 10 days after end of sampling period		

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381 Website: www.dhs.state.or.us/publichealth/dwp/index.cfm