



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
10/03	7.69				Y
10/17	7.71				Y
10/30	7.71				Y

<<Have minimums been met for this day?

County: Lane Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4192804

USFS MCKENZIE RANGER STATION

Sample period: 10/24
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Kenny Gabriel
Signature: *Kenneth Gabriel*
Date: 11/10/2024

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period