



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	COND	TEMP	Y/N
1					
2					
3					
4	8.1	90.0	232.1	13.2	Y
5					
6					
7					
8					
9					
10					
11	8.0	85.0	229.3	13.3	Y
12					
13					
14					
15					
16					
17					
18					
19	8.3	82.5	233.3	13.1	Y
20					
21					
22					
23					
24					
25	8.0	75.0	227.4	13.2	Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: COLUMBIA COUNTY

**ENTRY POINT**  
**EP-A**  
**PWS ID 4193427**  
**DYNO NOBEL INC**

Sample period: January 2021  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Cindy Mathews  
Signature: *Cindy Mathews*  
Date & Phone#: 2/3/2021

Send to DWP within 10 days after end of sampling period.

(No = N = Excursion) Total N's 0