

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	COND	TEMP	Y/N
1	7.91	86.1	259.5	14.2	Y
2					
3					
4					
5					
6					
7					
8	7.92	99.3	269.7	13.3	Y
9					
10					
11					
12					
13					
14					
15					
16	7.49	103.6	270.0	12.8	Y
17					
18					
19					
20					
21					
22					
23	7.93	104.8	278.0	14.1	Y
24					
25					
26					
27					
28					
29					
30	8.2	101.3	268.0	13.5	Y
31					

<<Have
minimums
been met for
this day?

County: Columbia Agency: COLUMBIA COUNTY

ENTRY POINT

EP-A

PWS ID 4193427

DYNO NOBEL INC

Sample period: March 2021
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH 7.2

Print Name: Mitchell Fargher

Signature: Mitchell Fargher

Date & Phone#: 4/1/2021 503-366-8920

Send to DWP within 10 days after end of
sampling period.

(No = N = Excursion) Total N's 0