

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	COND	TEMP	Y/N
1					
2					
3					
4					
5	7.67	93.6	244.2	17.1	Y
6					
7					
8					
9					
10					
11					
12	8.05	98.2	256.1	13.5	Y
13					
14					
15					
16					
17					
18					
19	7.73	100.2	248.3	13.7	Y
20					
21					
22					
23					
24					
25					
26	8.11	98.4	253.9	14.1	Y
27					
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Columbia Agency: COLUMBIA COUNTY

ENTRY POINT

EP-A

PWS ID 4193427

DYNO NOBEL INC

Sample period: April 2021
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH 7.2

Print Name: Mitchell Fargher

Signature: Mitchell Fargher

Date & Phone#: 5/5/2021 503-366-8920

Send to DWP within 10 days after end of
sampling period.

(No = N = Excursion) Total N's 0