

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	COND	TEMP	Y/N
1					
2					
3	7.73	97.6	265.5	20.9	Y
4					
5					
6					
7					
8					
9	7.73	96.9	261.7	22.6	Y
10					
11					
12					
13					
14					
15					
16					
17	7.91	103.7	266.7	18.7	Y
18					
19					
20					
21					
22	7.62	98.2	264.0	17.5	Y
23					
24					
25					
26					
27					
28					
29					
30	7.61	96.5	261.7	18.9	Y
31					

<<Have
minimums
been met for
this day?

County: Columbia Agency: COLUMBIA COUNTY

ENTRY POINT

EP-A

PWS ID 4193427

DYNO NOBEL INC

Sample period: August 2021
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH 7.2

Print Name: Mitchell Fargher

Signature: *Mitchell Fargher*

Date & Phone#: 9/2/2021 503-366-8920

Send to DWP within 10 days after end of
sampling period.

(No = N = Excursion) Total N's 0