

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	COND	TEMP	Y/N
1					
2					
3					
4	7.87	84.6	244.6	18.3	Y
5					
6					
7					
8					
9					
10					
11	7.65	86.2	238.9	17.6	Y
12					
13					
14					
15					
16					
17					
18	7.82	89.9	237.2	18.9	Y
19					
20					
21					
22					
23					
24					
25	7.55	76.2	224.7	17.2	Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: COLUMBIA COUNTY

**ENTRY POINT**  
**EP-A**  
**PWS ID 4193427**  
**DYNO NOBEL INC**

Sample period: October 2021  
*Month/Year*

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

Minimum Water Quality  
 Parameter(s) as set by State:

pH 7.2

Print Name: Mitchell Fargher  
 Signature: *Mitchell Fargher*  
 Date & Phone#: 11/2/2021 503-366-8920

Send to DWP within 10 days after end of sampling period.

(No = N = Excursion) Total N's 0