



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	COND	TEMP	Y/N
1					
2					
3	8.26	89.8	267.9	13.6	Y
4					
5					
6					
7					
8					
9					
10					
11	8.24	92.8	280.2	15.4	Y
12					
13					
14					
15					
16					
17					
18	8.16	89.6	273.6	15.1	Y
19					
20					
21					
22					
23					
24	7.71	86.8	267.6	13.4	Y
25					
26					
27					
28					
29					
30					
31	7.78	91.4	272.2	15.4	Y

<<Have minimums been met for this day?

County: Columbia Agency: COLUMBIA COUNTY

**ENTRY POINT**  
**EP-A**  
**PWS ID 4193427**  
**DYNO NOBEL INC**

Sample period: January 2022  
*Month/Year*

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Mitchell Fargher  
 Signature: *Mitchell Fargher*  
 Date & Phone#: 2/3/2022 503-366-8920

Send to DWP within 10 days after end of sampling period.

(No = N = Excursion) Total N's 0