

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	COND	TEMP	Y/N
1					
2					
3					
4					
5					
6					
7	7.77	89.6	274.1	13.9	Y
8					
9					
10					
11					
12					
13					
14	7.66	90.5	278.5	13.8	Y
15					
16					
17					
18					
19					
20					
21	7.71	92.8	264.4	14.5	Y
22					
23					
24					
25					
26					
27					
28	7.92	97.9	275.7	19.3	Y
29					
30					
31					

<<Have  
minimums  
been met for  
this day?

County: Columbia Agency: COLUMBIA COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193427**

**DYNO NOBEL INC**

Sample period: March, 2022  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

*Reference*

Minimum Water Quality  
Parameter(s) as set by State:

pH 7.2

Print Name: Heather Ebert

Signature: Heather Ebert

Date & Phone#: 3/30/22 503-366-8919

Send to DWP within 10 days after end of  
sampling period.

(No = N = Excursion) Total N's 0