



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	COND	TEMP	Y/N
1					
2					
3					
4	7.67	86.1	235.3	12.8	Y
5					
6					
7					
8					
9					
10					
11	7.78	82.1	226.5	13.1	Y
12					
13					
14					
15					
16					
17					
18					
19	7.74	92.9	246.1	17.2	Y
20					
21					
22					
23					
24					
25					
26					
27	7.80	73.3	210.4	12.8	Y
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Columbia Agency: COLUMBIA COUNTY

ENTRY POINT

EP-A

PWS ID 4193427

DYNO NOBEL INC

Sample period: December 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH 7.2

Print Name: Heather Ebert
Signature: Heather Ebert
Date & Phone#: 1/4/23 503-366-8919

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>