

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	COND	TEMP	Y/N
1					
2					
3	8.20	90.0	282.7	13.6	Y
4					
5					
6					
7					
8	7.89	94.3	269.2	13.3	Y
9					
10					
11					
12					
13					
14					
15					
16	7.65	93.7	271.3	10.8	Y
17					
18					
19					
20					
21					
22	7.83	97.4	284.0	13.2	Y
23					
24					
25					
26					
27					
28					
29	7.76	94.2	272.0	14.3	Y
30					
31					

<<Have  
minimums  
been met for  
this day?

County: Columbia Agency: COLUMBIA COUNTY

ENTRY POINT

EP-A

PWS ID 4193427

DYNO NOBEL INC

Sample period: January 2024  
Month Year

Number of excursions during this month: 0  
(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

### Reference

Minimum Water Quality  
Parameter(s) as set by State:

pH 7.2

Print Name: Heather Ebert

Signature: Heather Ebert

Date & Phone#: 2/1/24 503-366-8919

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0